



**OKLAHOMA CORPORATION COMMISSION
PETROLEUM STORAGE TANK DIVISION
(405) 521-4683 FAX: (405) 521-4945**

**SUMMARY OF SIGNIFICANT RULE CHANGES
EFFECTIVE SEPTEMBER 11, 2017**

1. All leak detection records must be kept for 3 years and be available to the PSTD Fuel Specialist (Inspector) when he is at the facility for an inspection. This includes all records for sampling, testing, inventory, and/or monitoring. These records may be kept offsite as long as they can be sent electronically to the facility at the time the inspector is there. Records that are locked in an office and not accessible to employee(s) when the inspector is there are considered to be not available and may result in a Notice of Violation (NOV). (OAC 165:25-1-53)
2. Written documentation of all calibration, maintenance and/or repairs to your release detection equipment must be kept for 3 years at the facility for the PSTD Fuel Specialist to review when he is there for an inspection. Schedules of calibration and maintenance that come from your release detection equipment manufacturer must be retained for 5 years from the date of installation. (OAC 165:25-1-56)
3. Before fuel is transferred from the transporter's truck into a storage tank, you must ensure that the volume available in the tank (this is the ullage portion of the tank) is greater than the amount of fuel being transferred into the tank; and that the transfer operation is monitored constantly to prevent spilling and overfilling. (OAC 165:25-2-39)
4. Any spill or overfill that is less than 25 gallons must be contained and immediately cleaned up within 24 hours. If the spill or overfill cannot be cleaned up within 24 hours, if it is more than 25 gallons, or if it causes a sheen on any nearby surface water, you must report the incident to the PSTD and begin taking corrective action measures. (OAC 165:25-2-39)
5. If you are replacing at least 50% of your underground piping it must be non-metallic and double-walled; a tracer locator wire must be installed in all piping trenches; and tank, dispenser, and transition sumps must be installed and monitored. If a metallic line fails due to corrosion, all metallic product lines at the facility must be immediately removed and cannot be repaired. (OAC 165:25-2-55.1)
6. All petroleum storage tanks, including any compartments within a compartmentalized tank that are not in use, must be monitored at least once every 30 days using one of the methods or combination of methods listed in Chapter 25, Subchapter 3, Part 2. (OAC 165:25-3-6.20)

If you have questions about the requirements for the operation and maintenance of your petroleum storage tank system please contact the Petroleum Storage Tank Division Compliance Department at (405) 521-4683.

**TO REPORT A RELEASE OR A SUSPECTED RELEASE CALL THE PSTD WITHIN 24 HOURS
(405) 521-4683 OR TOLL FREE (888) 621-5878
IF AFTER HOURS OR ON WEEKENDS OR HOLIDAYS CALL THE PSTD EMERGENCY PHONE
(405) 823-0994**