

Comments on  
Oklahoma Proposed  
Underground Storage Tank Regulations  
Chapter 25

Case RM 201600011

OCC Court Clerk's Office  
2101 N. Lincoln Blvd.  
Oklahoma City, OK 73105

**FILED**  
OCT 04 2016

COURT CLERK'S OFFICE - OKC  
CORPORATION COMMISSION  
OF OKLAHOMA

**165:25-2-133 Temporary removal from service**

(b) When an underground storage tank system is taken out of service for 3 months or more, but less than 12 months, the owner or operator must meet the following additional requirements:

~~(1) All tanks must be drained to less than one inch (1) of residue remaining in the tank. Release detection is not required as long as the underground storage tank is emptied to less than one inch (1).~~

(1) All tanks with less than 1 inch of residue are not required to perform monthly leak detection. Tanks with 1 inch or more of residue are required to perform monthly leak detection.

Add; (4) Lock all fill caps.

**165:25-2-133 (c) Insert:**

(1) Spill bucket testing

(2) Overfill prevention inspections

Submitted by:



Alex Ralston, POE  
Petcon, Inc.  
P.O. Box 6225  
Jackson, MS 39288

601-939-7311  
[petconinc@comcast.net](mailto:petconinc@comcast.net)