

Comments on
Oklahoma Proposed
Underground Storage Tank Regulations
Chapter 25

Case RM 201600011

OCC Court Clerk's Office
2101 N. Lincoln Blvd.
Oklahoma City, OK 73105

FILED
OCT 04 2016
COURT CLERK'S OFFICE - OKC
CORPORATION COMMISSION
OF OKLAHOMA

Add:

165:25-3-6.21 (d) ((5)) Hand-held electronic sampling equipment associated with groundwater and vapor monitoring: have the electronic instrument calibrated and tested by a third party to ensure proper operation.

165:25-2-36 (b) (1) (f) The pit bottom of the excavation must contain a smooth, evenly graded bed of appropriate bedding material covering the entire bottom of the excavation.

Submitted by:



Alex Ralston, POE
Petcon, Inc.
P.O. Box 6225
Jackson, MS 39288
601-939-7311
petconinc@comcast.net