

Comments on
Oklahoma Proposed
Underground Storage Tank Regulations
Chapter 25

FILED
SEP 30 2016
COURT CLERK'S OFFICE - OKC
CORPORATION COMMISSION
OF OKLAHOMA

Case RM 201600011

OCC Court Clerk's Office

2101 N. Lincoln Blvd.

Oklahoma City, OK 73105

Correct:

165-25-8-36 Fire Extinguishers

a. Each marina must be provided with listed fire extinguishers that have a minimum total capacity of 40 pounds, Class B, C. rating of 40BC.

NFPA does not mention that the fire extinguisher be listed in the fire code. I do not believe that UL lists fire extinguishers.

40 designates the area in sq. ft. over a surface with no depth to the liquid. 40 does not designate pounds.

B indicates a fire of flammable or combustible liquids

C indicated a fire of live electrical components.

References to justify the comments:

1. NFPA 10-2013 Standard for Portable Fire Extinguishers
2. OCC UST Removal Guidebook July 2004 page 6.

Submitted by:

A handwritten signature in black ink, appearing to read "A Raalston". The signature is fluid and cursive, with a large initial "A" and a long, sweeping tail.

Alex Raalston, POE

Petcon, Inc.

P.O. Box 6225

Jackson, MS 39288

601-939-7311

petconinc@comcast.net