

Comments on Proposed Rules
for Chapter 26

RM 201800006

Comments offered by:
Alex Ralston
Petcon, Inc.

1. **165-26-2-42 Frequency and criteria of inspections and tests**

- (4) All personnel performing cathodic protection system testing must have the required education, current corrosion certification experience...

I have added current to the proposed rule change. Corrosion certifications are typically for 3 years and must renewed every 3 years to remain current. The cathodic protection tester should be current in his certification. It makes no sense to have an individual that took a course 10 years ago and has not maintained the certification.

FILED
NOV 19 2018

COURT CLERK'S OFFICE - OKC
CORPORATION COMMISSION
OF OKLAHOMA